

Jersey Central Power & Light Instant Discounts Program

About the program

The Instant Discounts Program provides participating HVAC distributors/vendors incentives for selling qualified HVAC equipment to end users or contractors serving end users. Distributors receive incentives from JCP&L, which they pass along to customers/contractors. Instant discounts are available for existing buildings only. New construction projects are not eligible.

HVAC Equipment Instant Discount Requirements

1. Instant Discounts are provided at the distributor/vendor level.
2. A customer seeking an incentive for these products must seek out an eligible distributor or contractor who works with an eligible distributor. For a list of distributors, please visit: https://bizsolutions.energysaveNJ.com/wp-content/uploads/2023/07/BR_Instant-Discounts-Distributor-List_v7.pdf.

For more information on all our offerings, visit bizsolutions.energysaveNJ.com or contact us at 866-527-5249 or energysaveNJ@trccompanies.com.

HVAC EQUIPMENT			
HVAC Equipment Description	Qualifying Efficiency	Incentive	Energy Efficiency Requirements
UNITARY HVAC - SINGLE PACKAGE OR SPLIT SYSTEM			
Unitary HVAC Single Package System, <5.4 Tons, Tier 1	≥15.2 SEER2 ≥11.5 EER2	See Distributors for Incentive Amounts	ENERGY STAR Certified ASHRAE 90.1 -2019
Unitary HVAC Single Package System, <5.4 Tons, Tier 2	≥17.1 SEER2 ≥11.5 EER2		
Unitary HVAC Split System, <5.4 Tons, Tier 1	≥15.2 SEER2 ≥12 EER2		
Unitary HVAC Split System, <5.4 Tons, Tier 2	≥17.1 SEER2 ≥12 EER2		
Unitary HVAC Single and Split Package System, ≥ 5.4 Tons and < 11.25 Tons, Tier 1 and Tier 2	Electric Resistance or No Heating ≥15.5 IEER ≥11.8 EER	See Distributors for Incentive Amounts	ASHRAE 90.1 -2019
	Fossil Fuels and All Other ≥15.3 IEER ≥11.6 EER		
Unitary HVAC Single and Split Package System, ≥ 11.25 Tons and < 20 Tons, Tier 1 and Tier 2	Electric Resistance or No Heating ≥14.9 IEER ≥11.6 EER	See Distributors for Incentive Amounts	ASHRAE 90.1 -2019
	Fossil Fuels and All Other ≥14.7 IEER ≥11.3 EER		
Unitary HVAC Single and Split Package System, ≥ 20 Tons and < 63.3 Tons, Tier 1 and Tier 2	Electric Resistance or No Heating ≥13.9 IEER ≥10.5 EER	See Distributors for Incentive Amounts	ASHRAE 90.1 -2019
	Fossil Fuels and All Other ≥13.7 IEER ≥10.3 EER		
Unitary HVAC Single and Split Package System, ≥ 63.3 Tons, Tier 1 and Tier 2	Electric Resistance or No Heating ≥13.1 IEER ≥10.2 EER	See Distributors for Incentive Amounts	ASHRAE 90.1 -2019
	Fossil Fuels and All Other ≥12.9 IEER ≥10 EER		

Jersey Central Power & Light Instant Discounts Program

HVAC EQUIPMENT			
HVAC Equipment Description	Qualifying Efficiency	Incentive	Energy Efficiency Requirements
AIR SOURCE HEAT PUMP - SINGLE PACKAGE OR SPLIT SYSTEM			
Air Source Heat Pump, Single Package, <5.4 Tons, Tier 1	≥15.2 SEER2 ≥10.6 EER2 ≥7.2 HSPF2	See Distributors for Incentive Amounts	ENERGY STAR Certified ASHRAE 90.1 -2019
Air Source Heat Pump, Single Package, <5.4 Tons, Tier 2	≥17.1 SEER2 ≥10.6 EER2 ≥7.2 HSPF2		
Air Source Heat Pump, Split System, <5.4 Tons, Tier 1	≥15.2 SEER2 ≥11.7 EER2 ≥7.8 HSPF2		
Air Source Heat Pump, Split System, <5.4 Tons, Tier 2	≥17.1 SEER2 ≥11.7 EER2 ≥7.8 HSPF2		
Air Source Heat Pump, Single and Split Packaged System, ≥ 5.4 Tons and < 11.25 Tons, Tier 1 and Tier 2	Electric Resistance or No Heating ≥14.8 IEER ≥11.6 EER ≥3.6 COP	See Distributors for Incentive Amounts	ASHRAE 90.1 -2019
	Fossil Fuels and All Other ≥14.6 IEER ≥11.3 EER ≥3.6 COP		
Air Source Heat Pump, Single and Split Packaged System, ≥ 11.25 Tons and < 20 Tons, Tier 1 and Tier 2	Electric Resistance or No Heating ≥14.2 IEER ≥11.1 EER ≥3.5 COP	See Distributors for Incentive Amounts	ASHRAE 90.1 -2019
	Fossil Fuels and All Other ≥14 IEER ≥10.9 EER ≥3.5 COP		
PACKAGED TERMINAL AIR CONDITIONERS OR HEAT PUMPS			
Single Package Vertical Air Conditioner, < 5.4 Tons, Tier 1	≥11.6 EER	See Distributors for Incentive Amounts	ASHRAE 90.1 -2019
Single Package Vertical Air Conditioner, < 5.4 Tons, Tier 2	≥12.4 EER		

Jersey Central Power & Light Instant Discounts Program

HVAC EQUIPMENT			
HVAC Equipment Description	Qualifying Efficiency	Incentive	Energy Efficiency Requirements
PACKAGED TERMINAL AIR CONDITIONERS OR HEAT PUMPS			
Packaged Terminal Air Conditioner, < 7,000 BTU/h	≥12.5 EER	See Distributors for Incentive Amounts	ASHRAE 90.1 -2019
Packaged Terminal Air Conditioner, ≥ 7,000 BTU/h ≤ 15,000 Btu/h	≥10.9 EER		
Packaged Terminal Air Conditioner, > 15,000 BTU/h	≥10 EER		
Packaged Terminal Heat Pump, < 7,000 BTU/h PTHP ≥ 7,000 BTU/h ≤ 15,000 Btu/h	≥12.5 EER ≥3.5 COP	See Distributors for Incentive Amounts	ASHRAE 90.1 -2019
Packaged Terminal Heat Pump, ≥ 7,000 BTU/h ≤ 15,000 Btu/h	≥10.9 EER ≥3.2 COP		
Packaged Terminal Heat Pump, > 15,000 BTU/h	≥10 EER ≥3 COP		
DUCTLESS MINI SPLIT AIR CONDITIONER OR HEAT PUMP			
Ductless Mini-Split Air Conditioner, Tier 1	≥11.6 EER	See Distributors for Incentive Amounts	ASHRAE 90.1 -2019
Ductless Mini-Split Heat Pump, Tier 2	≥12.4 EER		
DUCTLESS MINI SPLIT AIR CONDITIONER OR HEAT PUMP			
Smart Thermostat	Product must be UL Listed, or listed by equivalent OSHA Nationally Recognized Testing Laboratory (NRTL).	See Distributors for Incentive Amounts	ASHRAE 90.1 -2019
Occupancy Controlled Thermostat - Electric			
Dual Enthalpy Economizer Controls	Control or Thermostat must be installed on electric HVAC equipment only.		